



NHBC, Buildmark House, Chiltern Avenue, Amersham, Bucks HP6 5AP
Tel: 0870 241 4302 Fax: 01494 735201 DX: 50712 Amersham www.nhbc.co.uk

Glanville Norman
National Agilia Manager
Lafarge Aggregates Ltd
Technical Centre
Gibbet Lane
Lutterworth
Leicestershire LE17 6AA

Direct Tel: 01494 735730
Direct Fax: 01494 735717
E-mail: Gsangarapillai@nhbc.co.uk
Ref: GS/em/2.1c
Date: 20 January 2006

Dear Glanville

Agilia Screed A (Gyvlon) and Agilia Screed C Steel

I thank you for your letter of 18 January and confirm that NHBC is now able to accept the use of Agilia Screed A (Gyvlon) and Agilia Screed C Steel on concrete floor slabs in accordance with your letter.

In addition NHBC requires the following.

1. Agilia Screeds will be used in accordance with NHBC Standards Chapter 8.3.
2. The following procedures will be adopted on site by the Lafarge licensee:
 - Provide "Installation site checklist"
 - State "Target workability" until this information is included in the delivery ticket.
 - Ascertain the "Slump-flow value" for each delivery prior to pumping the screed meets the target workability.
 - Ensure the surface regularity is within ± 8 mm of maximum deviation from a 2 m straight edge.

I trust that this letter sets out the NHBC requirements for the acceptance of Agilia Screed A (Gyvlon) and Agilia Screed C Steel.

Yours sincerely

Gopal Sangarapillai
Engineer, NHBC Technical

Raising house-building standards for homebuyers

National House-Building Council is a company no. 320784 limited by guarantee, registered in England. NHBC registered office:
Buildmark House, Chiltern Avenue, Amersham, Bucks HP6 5AP.
NHBC is authorised and regulated by the Financial Services Authority



INVESTOR IN PEOPLE